
## **ENERGY AUDIT REPORT**

of

Harikisan Jajoo Education Sanstha's

# College of Management & Computer Science

Naringe Nagar, Dhamangaon Road, Yavatmal 445 001



Year: 2022-23

Prepared by:

#### **ENGRESS SERVICES**

Yashashree, 26, Nirmal Bag Society
Near Muktangan English School, Parvati, Pune 411009
Phone: 09890444795 Email: engress123@gmail.com



## **ENGRESS SERVICES**

Yashashree, 26, Nirmal Bag Society, Near Muktangan English School, Parvati, Pune 411 009

Tel: 09890444795 Email: engress123@gmail.com

MEDA Registration No: ECN/2022-23/CR-43/1709 ISO: 9001-2015 Certified (Cert No: 23EQKC13) ISO: 14001-2015 Certified (Cert No: 23EEKW20)

## **ENERGY AUDIT CERTIFICATE**

Certificate No: ES/CMCS/22-23/01 Date: 21/10/2023

This is to certify that we have conducted an Energy Audit at College of Management & Computer Science, Yavatmal, in the Year 2022-23.

.The Institute has adopted following Energy Efficient practices:

- Usage of Energy Efficient LED Fittings
- Maximum usage of Day Lighting
- > Installation of 15 kWp Solar PV Plant

We appreciate the support of Management, involvement of faculty members and students in the process of making the Campus Energy Efficient.

For Engress Services,

AMehandal


A Y Mehendale,

B E-Mechanical, M Tech- Energy

BEE Certified Energy Auditor, EA-8192

#### **Registration Certificates**





#### **AUDITOR Certificate**



ISO: 9001-2015 Certificate

#### **MEDA Registration Certificate**



ISO: 14001-2015 Certificate



#### INDEX

Sr. No	Particulars	Page No
Ĭ,	Acknowledgement	5
Ш	Executive Summary	6
Ш	Abbreviations	7
1	Introduction	8
2	Study of Connected Load	9
3	Study of Present Energy Consumption	10
4	Study of Energy Performance Index	11
5	Study of Lighting	12
6	Study of Renewable Energy & Energy Efficiency	14



#### **ACKNOWLEDGEMENT**

We Engress Services, Pune, express our sincere gratitude to the management of College of Management & Computer Science, Yavatmal for awarding us the assignment of Energy Audit of their Campus for the Year: 2022-23.

We are thankful to all the staff members for helping us during the field study.



#### **EXECUTIVE SUMMARY**

- College of Management & Computer Science, Yavatmal consumes Energy in the form of Electrical Energy; used for various Electrical Equipment, office & other facilities.
- 2. Present Connected Load & Annual Energy Consumption:

No	Particulars	Value	Unit
1	Total Connected Load	51	kW
2	Annual Energy Consumption	21128	kWh
3	Annual CO <sub>2</sub> Emissions	19.01	MT

#### 3. Energy Performance Index:

No	Particulars	Value	Unit
1	Total Annual Energy Consumed	21128	kWh
2	Total Built up area of Institute	3276.58	m²
3	Energy Performance Index =(1) / (2)	6.44	kWh/m²

4. Study of Lighting Power Density & % of LED Lighting:

No	Particulars	Value	Unit
1	Lighting Power Density	1.06	W/m²
2	% of Usage of LED Lighting to Total Lighting Load	67.33	%

#### 5. Renewable Energy & Energy Efficiency Projects:

- Usage of Energy Efficient LED Fittings
- > Maximum usage of Day Lighting
- > Installation of 15 KWp Solar Power Plant

#### 6. Assumption:

1. 1 kWh of Electrical Energy releases 0.9 Kg of CO2 into atmosphere

#### 7. References:

Audit Methodology: <u>www.mahaurja.com</u>

Energy Conservation Building Code: ECBC-2017: www.beeindia.gov.in

For CO<sub>2</sub> Emissions: www.tatapower.com



#### **ABBREVIATIONS**

LED : Light Emitting Diode

MSEDCL : Maharashtra State Electricity Distribution Company Limited

BEE : Bureau of Energy Efficiency

ECBC : Energy Conservation Building Code

MEDA : Maharashtra Energy Development Agency

PV : Photo Voltaic Kg : Kilo Gram

kWh : kilo-Watt Hour CO<sub>2</sub> : Carbon Di Oxide

MT : Metric Ton


### CHAPTER-I INTRODUCTION

#### 1.1 Introduction:


An Energy Audit is conducted at College of Management & Computer Science, Yavatmal. The guidelines followed for conducting the Energy Audit are:

- BEE India's Energy Conservation Building Code: ECBC-2017
- Maharashtra Energy Development Agency (<u>www.mahaurja.com</u>)
- Tata Power: <u>www.tatapower.com</u>

#### 1.2 Audit Procedural Steps:



#### 1.3 Institute Location Image:





Engress Services, Pune


## CHAPTER-II STUDY OF CONNECTED LOAD

The major contributors to the connected load of the Institute include:

Table No 1: Study of Equipment wise Connected Load:

No	Equipment	Qty	Load, W/Unit	Load, kW
1	40 W FTL	39	40	1.56
2	12 W LED Round Fixtures	8	12	0.096
3	18 W LED Round Fixtures	10	18	0.18
4	20 W LED	75	20	1.5
5	Ceiling Fan	119	65	7.735
6	Wall Mount Fan	12	55	0.66
7	Air Conditioners (1.5TR 5 Star)	3	840	2.52
8	Computers	120	150	18
9	Printer	18	150	2.7
10	Water Pump	1	1492	1.492
11	Other Equipment	100	150	15
12	Total			51

Chart No 1: Study of Connected Load:



Page 9

Engress Services, Pune

## CHAPTER-III STUDY OF PRESENT ENERGY CONSUMPTION

In this chapter, we present the analysis of Electrical Energy Consumption. Table No 2: Electrical Bill Analysis- 2022-23:

No	Month	Energy Consumed, kWh	CO2 Emissions, MT
1	Apr-22	1273	1.145
2	May-22	1529	1.376
3	Jun-22	2638	2.374
4	Jul-22	1894	1.704
5	Aug-22	1796	1.616
6	Sep-22	2941	2.646
7	Oct-22	1772	1.594
8	Nov-22	1716	1.544
9	Dec-22	1675	1.507
10	Jan-23	1311	1.179
11	Feb-23	624	0.561
12	Mar-23	1959	1.763
13	Total	21128	19.015
14	Maximum	2941	2.646
15	Minimum	624	0.561
16	Average	1760.66	1.584

Chart No 2: Variation in Monthly Energy Consumption:





Engress Services, Pune

Table No 3: Important Parameters:

No	Parameter/ Variation	Energy Consumed, kWh	CO₂ Emissions, MT
1	Total	21128	19.015
2	Maximum	2941	2.646
3	Minimum	624	0.561
4	Average	1760.66	1.584

Page 11

## CHAPTER-IV STUDY OF ENERGY PERFORMANCE INDEX

**Energy Performance Index:** Energy Performance Index of a Building is its Annual Energy Consumption in Kilo Watt Hours per square meter of the Building

It is determined by:

EPI = (<u>Annual Energy Consumption in kWh</u>) (Total Built-up area in m²)

Now we compute the EPI for the Institute as under:

Table No4: Computation of Energy Performance Index:

No	Particulars	Value	Unit
1	Total Annual Energy Consumed	21128	kWh
2	Total Built up area of Institute	3276.58	m²
3	Energy Performance Index =(1) / (2)	6.44	kWh/m²



## CHAPTER V STUDY OF LIGHTING

#### Terminology:

- 1. Lumen is a unit of light flow or luminous flux. The lumen rating of a lamp is a measure of the total light output of the lamp. The most common measurement of light output (or luminous flux) is the lumen. Light sources are labeled with an output rating in lumens.
- 2. Lux is the metric unit of measure for illuminance of a surface. One lux is equal to one lumen per square meter.
- 3. Circuit Watts is the total power drawn by lamps and ballasts in a lighting circuit under assessment.
- **4. Installed Load Efficacy** is the average maintained illuminance provided on a horizontal working plane per circuit watt with general lighting of an interior. Unit: lux per watt per square metre (lux/W/m²)
- **5. Lamp Circuit Efficacy** is the amount of light (lumens) emitted by a lamp for each watt of power consumed by the lamp circuit, i.e. including control gear losses. This is a more meaningful measure for those lamps that require control gear. Unit: lumens per circuit watt (lm/W)
- **6. Installed Power Density.** The installed power density per 100 lux is the power needed per square metre of floor area to achieve 100 lux of average maintained illuminance on a horizontal working plane with general lighting of an interior **Unit:** watts per square metre per 100 lux (W/m²/100 lux) 100 Installed power density (W/m²/100 lux)
- **7. Lighting Power Density:** It is defined as Total Lighting Load in a room divided by the Area of that Room in square meters.

In this Chapter we compute: Lighting Power Density of a Class Room. We also compute the percentage usage of LED Lighting to total Lighting Load of the Institute.

Table No 5: Computation of Lighting Power Density:

No	Particulars	Value	Unit
1	No of 20 W LED Tube Lights in Class Room	04	Nos
2	Demand of 20 W LED Tube Light	20	W/Unit
3	Total Lighting Load in the Class Room= (1) * (2)	80	W
4	Area of Class Room	50	m²
5	Lighting Power Density = (3)/ (4)	1.6	W/m²

Engress Services, Pune

Page 13

Now, we compute the usage of LED Lighting to Total Lighting Load, as under. Table No 6: Percentage Usage of LED Lighting to Annual Lighting Load:

No	Particulars	Value	Unit
1	No of 40 W FTL Light Fittings	39	Nos
2	Demand of 40 W FTL Light Fitting	40	W/Unit
3	Total Electrical Load of 40 W FTL Light Fittings	1.56	kW
4	No of 12 W LED Tube Lights	8	Nos
5	Demand of 12 W LED Tube Light	12	W/Unit
6	Total Electrical Load of 12 W LED Fittings	0.096	kW
7	No of 18 W LED Tube Lights	10	Nos
8	Demand of 18 W LED Tube Light	18	W/Uni
9	Total Electrical Load of 18 W LED Fittings	0.18	kW
10	No of 20 W LED Tube Lights	75	Nos
11	Demand of 20 W LED Tube Light	20	W/Uni
12	Total Electrical Load of 20 W LED Fittings	1.5	kW
13	No of 240 W LED Tube Lights	6	Nos
14	Demand of 240 W LED Tube Light	240	W/Uni
15	Total Electrical Load of 240 W LED Fittings	1.44	kW
16	Total Lighting Load=3+6+9+12+15	4.776	kW
17	Total LED Lighting Load= 6+9+12+15	3.216	kW
18	Annual Lighting Requirement met by LED= 14*100/13	67.3367	

## CHAPTER-VI STUDY OF RENEWABLE ENERGY & ENERGY EFFICIENCY

The Institute has installed a **15 kWp** capacity Roof top Solar PV Plant this year. Now we compute the Percentage of Alternate Energy to Annual Energy demand:

Table No 7: Computation of % Annual Energy Demand met by Alternate Energy:

No	Particulars	Value	Unit
1	Energy Purchased from MSEDCL	21128	kWh
2	Installed Roof Top Solar PV Plant Capacity	15	kWp
3	Average Daily Energy Generated	4	kWh/kWp
4	Annual Generation Days	300	Nos
5	Annual Solar Energy Generated	18000	kWh
6	Total Energy Demand = (1) + (5)	39128	kWh
7	Expecting % of Usage of Alternate Energy to Total Annual Energy Demand for Current Year Consumption= (5)*100/ (6)	46	%

#### Photograph of Roof Top Solar PV Plant:



Engress Services, Pune

Page 15